



Bucknalls Lane, Garston
Watford, Herts WD25 9BA
Tel: 01923 665300
Fax: 01923 665301
e-mail: testing@bba.star.co.uk
<http://www.bbacerts.co.uk>

BRITISH BOARD OF AGRÉMENT TEST REPORT No 58669

SOLATUBE INTERNATIONAL INC - SOLATUBE SKYLIGHTS

CONTENTS

- 1 Report conditions
- 2 Resistance to upward loads
- 3 Resistance to downward loads
- 4 Impact resistance, large soft body

Approved By:

Mark Beynon
(Senior Test Technician)

Date: 26 September 2016

Authorised By:

Stuart Sadler
(Head of Test)

Date: 03 October 2016

On behalf of the British Board of Agrément

Client: Solatube International, Inc
2210 Oak Ridge Way
Vista
CA 92081-8341
USA

Requested by: Luke Adams - BBA

Job No: T9 58669 (S2 58189)

Work Period: August to September 2016

1 REPORT CONDITIONS

1.1 This Report:

- relates only to the product/system and sample/specimen thereof named and described herein
- relates only to the specified tests and test conditions described herein
- is issued only to the company, firm, organisation or person named herein — no other company, firm, organisation or person may hold this Report or claim that it has been issued to them
- has to be read, considered and used as a whole document — it may be misleading and will be incomplete to be selective
- is copyright of the BBA
- is subject to English Law.

1.2 No verification of any of the materials, samples, specimens, information, data or documents supplied to the BBA has been made, except where otherwise stated.

1.3 Publications, documents, specifications and similar matter that are referred to herein, are those that were current at the date of issue of this Report, except where otherwise stated.

1.4 The BBA has used due skill, care and diligence in preparing this Report, but no warranty is given or implied.

1.5 In issuing this Report, the BBA is not responsible; and is excluded from any liability to any company, firm, organisation or person; for any matters arising directly or indirectly from:

- the presence or absence of any patent, intellectual property or similar rights subsisting in the product/system
- individual installations of the product/system, including their nature, design, methods, performance, workmanship and maintenance
- any works and constructions in which the product/system is installed, including their nature, design, methods, performance, workmanship and maintenance
- any loss or damage, including personal injury, howsoever caused by the product/system, including its manufacture, supply, installation, use, maintenance and removal.

1.6 This Report does not constitute or indicate any approval, certification or endorsement of the product/system.

2 RESISTANCE TO UPWARD LOADS

2.1 Method

In accordance with BS EN 1873 : 2014 +A1 : 2016 *Prefabricated accessories for roofing – Individual rooflights of plastic – Product specification and test methods*, Section 5.4.1 *Resistance to upward loads*.

The assessment is of the rooflight and its flashing/curb, it does not cover the attachment of the flashing/curb to the structure of the building.

Air pressure was used to apply the load.

2.2 Samples

BBA Ref/Lot	Quantity	Description
S2/58189/1	2	Solatube 290DS kit with acrylic dome kits, labelled as 2 of 290DS starter kits 121595.
S2/58189/2	2	Solatube tile roof flashing kits (290DS), labelled 5 of 290DS flashing 230880.
S2/58189/4	5	Solatube 750DS Acrylic dome kits, labelled 5 of 750DS dome acrylic bulk 510300.
S2/58189/5	3	Solatube sky vault M74DS-D polycarbonate dome kit, labelled 3 of M74DS Dual dome 126000.
S2/58189/6	5	Solatube 330/750DS tube rings, labelled 400500.
S2/58189/7	3	Solatube curb mount flashing 330DS.
S2/58189/8	5	(330/750) 21" PVC Dome ring, 400500.
S2/58189/11	3	330/750 no pitch flashing.

2.3 Results

Lot	Maximum load applied (N·m ²)	Observation	Class
1 & 2	3352	No visible damage.	UL3352
4 & 11 (6 & 8)	3352	No visible damage.	UL3352
4 & 7 (6 & 8)	3352	No visible damage.	UL3352
5 & 7	3352	No visible damage	UL3352

3 RESISTANCE TO DOWNWARD LOADS

3.1 Method

In accordance with BS EN 1873 : 2014 +A1 : 2016 *Prefabricated accessories for roofing – Individual rooflights of plastic – Product specification and test methods*, Section 5.4.2 *Resistance to downward loads*.

The assessment is of the rooflight and its flashing/curb, it does not cover the attachment of the flashing/curb to the structure of the building.

Weights were used to apply the load.

3.2 Samples

BBA Ref/Lot	Quantity	Description
S2/58189/1	2	Solatube 290DS kit with acrylic dome kits, labelled as 2 of 290DS starter kits 121595.
S2/58189/2	2	Solatube tile roof flashing kits (290DS), labelled 5 of 290DS flashing 230880.
S2/58189/4	5	Solatube 750DS Acrylic dome kits, labelled 5 of 750DS dome acrylic bulk 510300.
S2/58189/5	3	Solatube sky vault M74DS-D polycarbonate dome kit, labelled 3 of M74DS Dual dome 126000.
S2/58189/6	5	Solatube 330/750DS tube rings, labelled 400500.
S2/58189/7	3	Solatube curb mount flashing 330DS.
S2/58189/8	5	(330/750) 21" PVC Dome ring, 400500.
S2/58189/11	3	330/750 no pitch flashing.

3.3 Results

Lot	Maximum load applied (N·m ²)	Observation	Class
1 & 2	7182	No visible damage.	DL7182
4 & 11 (6 & 8)	7182	No visible damage.	DL7182
4 & 7 (6 & 8)	7182	No visible damage.	DL7182
5 & 7	7182	No visible damage	DL7182

4 IMPACT RESISTANCE, LARGE SOFT BODY

4.1 Method

In accordance with BS EN 1873 : 2014 +A1 : 2016 *Prefabricated accessories for roofing – Individual rooflights of plastic – Product specification and test methods*, Section 5.4.3.2 *Large, soft body impact*.

The assessment is of the rooflight and its flashing/curb, it does not cover the attachment of the flashing/curb to the structure of the building.

4.2 Samples

BBA Ref/Lot	Quantity	Description
S2/58189/3	1	Solatube 330DS Polycarbonate dome kit.
S2/58189/4	5	Solatube 750DS Acrylic dome kits, labelled 5 of 750DS dome acrylic bulk 510300.
S2/58189/5	3	Solatube sky vault M74DS-D polycarbonate dome kit, labelled 3 of M74DS Dual dome 126000.
S2/58189/6	5	Solatube 330/750DS tube rings, labelled 400500.
S2/58189/7	3	Solatube curb mount flashing 330DS.
S2/58189/8	5	(330/750) 21" PVC Dome ring, 400500.
S2/58189/11	3	330/750 no pitch flashing.

4.3 Results

Lot	Impact site	Drop height ⁽¹⁾ (m)	Observation	Class
4 & 11 (6 & 8)	Centre	2.75	No visible damage	SB1350
3 & 7 (6 & 8)	Centre	2.75	No visible damage	SB1350
5 & 7	Centre	2.75	No visible damage	SB1350

(1) Due to limitations on the test equipment used this was the maximum drop height achieved.